



## GAOM.EX5083

### Clean-agent Extinguishers

[Page Bottom](#)

---

### Clean-agent Extinguishers

[See General Information for Clean-agent Extinguishers](#)**ANSUL - A TYCO FIRE PROTECTION PRODUCTS BRAND**

EX5083

1 STANTON ST

MARINETTE, WI 54143-2542 USA

**Stored-pressure-type Extinguishers**

Model	Nominal Agent Capacity, lb	Min Use Temp, °F	Rating	Marine Type
<b>FE-36</b>				
FE02	2.5	-40	2-B: C	No
FE05+	4.75	-40	5-B: C	Yes
FE05S+	4.75	-40	5-B: C	Yes
FE09+	9.5	-40	1-A: 10-B: C	Yes
FE13+	13.25	-40	2-A: 10-B: C	Yes
FE13NM	13.25	-40	1-A: 10-B: C	No

+ FAA Approved in accordance with DOT/FAA/AR-01/37.

[Last Updated](#) on 2015-08-20[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2016 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".



## GAOM.GuidelInfo Clean-agent Extinguishers

[View Listings](#)

[Page Bottom](#)

### [Extinguishers and Extinguishing System Units] Clean-agent Extinguishers

[See General Information for Extinguishers and Extinguishing System Units](#)

#### USE AND INSTALLATION

This category covers clean-agent extinguishers, which are portable appliances intended for operation over a temperature range of -40°F to 120°F unless otherwise noted in the individual certifications.

Fire extinguishing classifications are developed at normal ambient temperature (approximately 70°F) and may be reduced at lower temperatures.

In using extinguishers of this type, especially in unventilated places, such as small rooms, closets or other confined spaces, operators and others should take precautions to avoid the effects which may be caused by breathing the gases or vapors liberated or produced.

These extinguishers are intended to be installed, maintained and tested in accordance with the applicable requirements of ANSI/NFPA 10, "Portable Fire Extinguishers," and the manufacturer's owner's manual.

Clean-agent fire extinguishers are intended to be used in accordance with the United States Environmental Protection Agency's (EPA) proposed rules for chemicals intended to replace stratospheric-ozone-depleting substances described in the Significant New Alternative Policy (SNAP) program.

#### PRODUCT IDENTITY

The following product identity appears on the product:

Clean-agent Fire Extinguisher - Classification [classification letter(s) and number(s)]

#### ADDITIONAL INFORMATION

For additional information, see Extinguishers and Extinguishing System Units ([FWFZ](#)) and Fire Protection Equipment ([AAFP](#)).

#### REQUIREMENTS

The basic standards used to investigate products in this category are [ANSI/UL 711](#), "Rating and Fire Testing of Fire Extinguishers," and [ANSI/UL 2129](#), "Halocarbon Clean Agent Fire Extinguishers."

#### UL MARK

The Certification Mark of UL on the product is the only method provided by UL to identify products manufactured under its Certification and Follow-Up Service. The [Certification Mark](#) for these products includes the UL symbol, the words "CERTIFIED" and "SAFETY," the geographic identifier(s), and a file number.

#### Alternate UL Mark

The Listing Mark of UL on the product is the only method provided by UL to identify products manufactured under its Listing and Follow-Up Service. The Listing Mark for these products includes the UL symbol (as illustrated in the Introduction of this Directory) together with the word "LISTED," a control number, and the product name "Clean Agent Fire Extinguisher - Classification \_\_\_\_."

\* \* \* \* \*

UL, in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. UL shall not incur any obligation or liability for any loss, expense or damages, including incidental or consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this Guide Information.

[Last Updated](#) on 2013-05-16

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2016 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".